

RESULTATEN

BASISBEREKENING

EPB-EENHEID	U/R-waarden	S-peil	E-peil	Ventilatie	Oververhitting	HE
Traphal 1	✓					
Traphal 2	✓					
A0.1	✓	29 (<31)	-12 (<35)	✓	2.584 (<6.500)	✓
A0.2	✓	26 (<31)	1 (<35)	✓	2.716 (<6.500)	✓
A0.3	✓	30 (<31)	-7 (<35)	✓	2.896 (<6.500)	✓
A1.1	✓	30 (<31)	13 (<35)	✓	2.191 (<6.500)	✓
A1.2	✓	26 (<31)	-9 (<35)	✓	2.093 (<6.500)	✓
A1.3	✓	25 (<31)	-21 (<35)	✓	2.161 (<6.500)	✓
A1.4	✓	31 (<31)	-9 (<35)	✓	3.449 (<6.500)	✓
A2.1	✓	31 (<31)	6 (<35)	✓	3.254 (<6.500)	✓
A2.2	✓	29 (<31)	12 (<35)	✓	2.451 (<6.500)	✓

INBEGREPEN IN BASISBEREKENING

Isolatie	Volgens plannen architect (zie hoofdstuk isolatie)
Luchtdichtheid	App. 2.1: goede score: 3 m ³ /h.m ² Overige app.: gemiddelde score: 5 m ³ /h.m ²
Verwarming & sanitair	Individuele lucht/water warmtepomp
Afgiftesysteem	Vloerverwarming
Koeling	Actieve koeling
Ventilatie	Systeem D Gemeten vermogen ventilator ≤ 135 W
Hernieuwbare energie	Zonnepanelen (hoeveelheid verschillend per appartement zie mail 2/12/2022)